



**NOTES:**

1. TO POWER SWF EQUIPMENT OFF AN EXISTING ILLUMINATION CIRCUIT, THE EXISTING ILLUMINATION CONDUCTORS SHALL BE DISCONNECTED FROM THE ASSOCIATED CONTACTOR AND ROUTED DIRECT TO THE ASSOCIATED BREAKER. PULL EXISTING CONDUCTORS BACK TO CLOSEST JUNCTION BOX TO SPLICE ADDITIONAL LENGTH AS NEEDED.
2. ALL STREETLIGHT POLES ON THE SAME CIRCUIT AS THE SWF POLE SHALL HAVE PHOTOCELLS INSTALLED. STREETLIGHT FIXTURES THAT ARE NOT COMPATIBLE WITH A 3-PIN TWIST-LOCK PHOTOCELL SHALL BE REPLACED.



SMALL WIRELESS FACILITY SHARED ILLUMINATION CIRCUIT

DRAWING NUMBER	SL-125-1
SCALE	NONE
REVISION DATE	5/21
DEPARTMENT	TRANS