



SOUTH AND WEST SIDE LIGHTING ARE ODD # LIGHTS & CONNECTED TO CONTACTOR #1
 NORTH AND EAST SIDE LIGHTING ARE EVEN # LIGHTS & CONNECTED TO CONTACTOR #2

PANEL SCHEDULE								
NO.	S			LOCATION: PEDESTAL PANEL SERVING: STREET LIGHTS, ETC.		120/240 VOLTS 1 PHASE 3 WIRE 150 AMP with MAIN BREAKER		
CKT NO.	LOAD DESCRIPTION	KVA	TRIP AMPS		TRIP AMPS	KVA	LOAD DESCRIPTION	CKT NO.
1	ODD # STREET LIGHTS		30		30		EVEN # STREET LIGHTS	2
5	INTERSECTION LIGHTS		30		30		SPARE/FUTURE	6
9	SMALL WIRELESS FACILITY		20		20		SMALL WIRELESS FACILITY	10
13	DUPLEX RECEPTACLE ODD # SL		20		20		DUPLEX RECEPTACLE EVEN # SL	14
15	GFCI		20		15		LIGHTING CONTROL	16
REMARKS:				CONNECTED LOAD:		KVA	AMPS	
				DEMAND LOAD:		KVA	AMPS	

PANEL SCHEDULE								
NO.	T			LOCATION: PEDESTAL PANEL SERVING: TRAFFIC SIGNAL CONTROL		120/240 VOLTS 1 PHASE 3 WIRE 50 AMP with MAIN LUGS ONLY		
CKT NO.	LOAD DESCRIPTION	KVA	TRIP AMPS		TRIP AMPS	KVA	LOAD DESCRIPTION	CKT NO.
1	SPARE/FUTURE				30		TRAFFIC SIGNAL CONTROL	2
3	SPACE						SPACE	4
REMARKS:				CONNECTED LOAD:		KVA	AMPS	
				DEMAND LOAD:		KVA	AMPS	



PANEL SCHEDULE

DRAWING NUMBER	SL-240-1
SCALE	NONE
REVISION DATE	5/21
DEPARTMENT	TRANS