

SPACING AS REQUIRED BY ENGINEER

3-2"x6" PLANKS FOR TRENCH WIDTH OF 8' OR LESS
3-4"x6" PLANKS FOR TRENCH WIDTH OVER 8' WIDE

PLACE MIN. OF 3' INTO UNDISTURBED SURFACE

FINISHED GRADE

4" MIN. ABOVE FINISHED GRADE

54" MIN.

ELEVATION

UNDISTURBED SURFACE

18" MIN.

MAXIMUM TRENCH WIDTH AT TOP

18" MIN.

2"x6" POSTS, MIN. 54" LONG

ONLY TOP PLANK TO EXTEND FULL DISTANCE AS SHOWN

PLAN



City of Bellevue

SEWER UTILITIES

TITLE

TIMBER BAFFLE/HILL HOLDER